

# Data sheet Raised floor type NORTEC L 38 x M

- 1 Raised floor panel
- 2 Plastic edge trim (optional)
- 3 Pedestal glue
- 4 Pedestal
- 5 Gasket

# System description

### Panel

fibre-reinforced calciumsulphate panel, surrounding edge trim protection against damage and humidity, edges inclined

#### Pedestal

wine accument is the intellectual property of Lindner, Amstorf. Without our approval, it may not be either reproduced or commercialised, distributed or presented to other individuals for connercial purpose without authorization to do so.

bject to chance without notice

precisely height adjustable, from galvanized and yellow chromatized steel, precision threaded bolt, various types according to height requirements

### Gasket from plastic material, vaulted surface for perfect panel fixing

- Height fixing
- Locking glue or machanical fixing Pedestal glue

Placing of pedestal base into glue pad

- · Finished floor heights above 500 mm, the use of stringers is recommended for better lateral stability
- Wall connection pre-stressed foam rubber, for acoustic insulation and absorption of horizontal movements
- Subfloor a 2 - component epoxy coating is recommended with ventilation

# Applications

- · Computer rooms and control rooms
- · Industry and working rooms
- Training and research rooms
- Office and construction areas

## Possible floor coverings°

- · elastic coverings
- · textile coverings
- WOODline, wood coverings
- STONEline, stone coverings
- · loose-laid / free-laid covering tiles

### Technical Data

Load and deflection class <sup>1</sup>

2A (3kN)

Reaction to fire performance <sup>2</sup>	A2
Fire resistance performance <sup>3</sup>	F 30
Electrostatic conductivity <sup>4</sup>	$\geq$ 1 x 10 <sup>6</sup> $\Omega$
Weight of system 5	62 kg/sqm
Pedestal heights <sup>6</sup>	28 - 2000 mm
Thickness of panel	38 mm
Pedestal grid	600 x 600 mm

Acoustic values according <sup>7</sup>	without covering	with covering
Normalized flanking level difference D $_{\rm n,f,w}$	54 dB	57 dB (VM=29 dB)
Weighted sound reduction index R $_{\rm W}$	62 dB	-
Reduction of impact sound pressure level $L_w$	12 dB	31 dB (VM=29 dB)
Normalized flanking impact sound pressure level L $_{n,f,w}$	70 dB	47 dB (VM=29 dB)

- 1 tested to DIN EN 12825 with safety factor 2, nominal load in brackets
- 2 tested to DIN 4102, A1 (fully non-combustible) tested to EN 13501 on request
- 3 tested to DIN 4102, up to 800 mm floor heights, as required F60, REI30 / REI60 tested to EN 13501
- 4 Values depending on floor covering
- 5 floor height 150 mm (FFH), without covering
- 6 installation height, special heights on request
- 7 laboratory tested, VDI 3762 is to be considered
- 8 Panels without edge trim available after consultation of productmanagement